

RESOLUTION NO. 2016-122

A RESOLUTION TO AUTHORIZE THE REPAIR OF TRICKLING FILTER PUMP #3

WHEREAS, Trickling Filter Pump #3 has been shutting down due to high temperatures; and

WHEREAS, pump #3 is the last of the three original trickling filter pumps; and

WHEREAS, the pump was sent to Kennedy Industries for evaluation as they are the manufacturer's representative in the State of Michigan for Flyght pumps; and

WHEREAS, the pump was disassembled to determine the needed repairs; and

WHEREAS, the estimate to fix the pump is \$4,687.00 plus an estimated \$1,000.00 to reinstall the pump; and

WHEREAS, the estimated cost of a new pump is approximately \$25,000.00; and

WHEREAS, we feel that this rebuilt pump will continue to serve us well until we can budget money for its replacement.

THEREFORE, BE IT RESOLVED That the City Council approve the rebuilding of the Trickling Filter Pump #3 by Kennedy Industries and it be paid for from the Water and Sewer Fund.